## **Certificate of Compliance**

Certificate Number **20080409-E164155C** 

Report Reference E164155, 1998 December 23

Issue Date 2008 April 9



Issued to: WERMA SIGNALTECHNIK GMBH + CO KG

**DUERBHEIMER STRASSE 15** 

78604 RIETHEIM-WEILHEIM, GERMANY

This is to certify that representative samples of

MISCELLANEOUS APPARATUS

Cat. Nos. 107, 108, followed by 000, 010, 001, or 005, may be followed by 55, 67, 68, 75, 77, or 78, may be followed by additional suffixes. 109 followed by 000 or 010 followed by 68,75 or 77 No. 110 followed by 000, followed by 75,67,68.

Have been investigated by Underwriters Laboratories Inc.® in accordance

with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL508 - Industrial control Equipment -17th Edition

CAN/CSA C22.2 No. 14-2005 - Industrial Control Equipment

Additional Information:

Electrical Ratings: 24 V ac/dc, 48 V ac/dc, 115 V ac/dc, 230 V ac input maximum,

less than 100 mA.

Enclosure Rating: Type 5 (Type 108), Type 4X (Type 107, 109 and 110)

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers: c the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: Nick Boten
Nick Boten, Engineering Aide
Underwriters Laboratories Inc.

Reviewed by: Tim Lueck

Tim Lueck, Associate Project Engineer

Underwriters Laboratories Inc.